

न्यूक्लियर पावर कॉर्पोरेशन ऑफ इंडिया लिमिटेड Nuclear Power Corporation of India Ltd.

(भारत सरकार का उद्यम A Govt. of India Enterprise)

नरौरा परमाणु विद्युत केंद्र Narora Atomic Power Station

नरौरा जिला बुलंदशहर (उ.प्र.) Narora, Distt. Bulandshahr (UP)

No. NAPS/SD/75/2015/S/242

Oct 26, 2015

**Subject: Report on Seismic Event of 26 Oct 2015**


A seismic event was reported today at 14.39 hrs., 256 Km North of Kabul, Afghanistan of magnitude 7.7 on Richter scale, as reported in TV News channels. NAPS Unit-1&2 continued to operate smoothly during the seismic event. The Digital Time History Accelerograph (DTHA) installed at free field in operating island did not record any event. The trigger level for the DTHA has been set at 0.01g (10 mg).

During the seismic event, Window Annunciation "SSS tank level low" from TK-304 appeared in Unit-1 and "SSS TK level high" from TK-104 & "SSS TK level low" from TK-204, appeared in Unit-2.

Area visit has been made to ascertain healthiness of systems. There was no indication of any effect on plant equipment and plant operation.

This is for your kind information please.

With regards,



(D. S. Choudhary)  
Station Director, NAPS

Sh. P.R. Krishnamurthy  
Director, OPSD, AERB,  
Niyamak Bhawan,  
Anushaktinagar, Mumbai.

Copy To: AERB

Chairman, SARCOP

NPCIL

CMD

Dir (O)/ ED (O-PHWR)

ED (CP & CC)

NAPS

CS

MS/TSS/OS

श्री वी. सी. शर्मा

श्री ए. के. शर्मा