

न्यूक्लियर पॉवर कॉर्पोरेशन ऑफ इंडिया लिमिटेड Nuclear Power Corporation of India Ltd.

(भारत सरकार का उद्यम A Govt. of India Enterprise)



नरौरा परमाणु विद्युत केंद्र Narora Atomic Power Station

नरौरा जिला बुलंदशहर (उ.प्र.) Narora, Distt. Bulandshahr (UP)

No. NAPS/SD/75/2013/SI 84

May 02, 2013

**Subject: Report on Seismic Event of 01 May 2013**

A seismic event was reported on May 1<sup>st</sup> at 12:27 hrs in 17 km North-East of Bhadarwah in Indian controlled Kashmir and Himachal Pradesh border of magnitude 5.8 on Richter scale, as reported in TV News channels. NAPS both units continued to operate smoothly during the seismic event. The Digital Time History Accelerograph (DTHA) installed at free field in operating island did not record any event. The trigger level for the DTHA has been set at 0.01g.

Moreover during the seismic event, no Window Annunciation appeared in main control room.

This is for your kind information please.

With regards,

Sh. P.R. Krishnamurthy  
Director, OPSD, AERB,  
Niyamak Bhawan,  
Anushaktinagar, Mumbai.

(S.K. Sharma)  
Station Director

Copy To: AERB  
Chairman, SARCOP

NPCIL  
CMD  
Dir (O)/ ED (O-PHWR)  
ED (CP & CC)

NAPS  
CS  
MS/TSS/OS